

Planning of SWER MV Networks

Bruce McLaren.
IARC
Eskom South Africa

Key planning issues (SWER)

Part 1 - Particular SWER parameters constraints)

- Loading, balance and interference constraints.
- Components and specific design parameters
- Ferranti resonance on SWER schemes
- Conductor selection


Part 2 – Emerging electrification plan approach

- Electrification plan (emerging)
- Detailed design reference based on the electrification plan - planning report.
- Project load estimates and upgrade considerations
- Unbalance considerations.

SWER Constraints

- **Peak Demand: 475 kVA (25A, 19.1kV)**
- **3% Unbalance on 3 Phase Network**
- **Voltage range at customer supply points - 230 V +/- 10%, viz. 207-253V.**
- **Telephone Interference**

Peak Current Meter



Break 1

Eskom SWER Design Parameters

Rated voltage 19.1 kV (33 kV phase-to-phase)

Maximum feeder current 25 A

Isolation transformers 50 kVA
100 kVA
200 kVA
400 kVA

Note: A 16kVA isolation transformer is not considered because of protection constraints and the small practical cost difference between a 16 kVA and 50 kVA isolation transformer.

Customer transformers 16 kVA single-phase
32 kVA dual-phase
64 kVA dual-Phase

Eskom SWER Design Parameters

Electrode voltage: (Refer earthing section)	rod type 100 V trench type 32 V	
Maximum touch potential	<32 V	
Line basic insulation level	>250 kV	
Equipment insulation level	>200 kV	
LV neutral MCOV (isolation transformer SWER)		5 kV
LV neutral MCOV (33 kV source SWER)		5 kV

Gapless surge arrester Ratings

V system	U max	MCOV	V res.	Earthing
11	12	10	40	Non effective
22	24	19.5	80	Non effective
33	36	24	100	Effective (SWER)
33	36	29	120	Non effective

Break 2

Voltage imbalance


Voltage Unbalance: Voltage Unbalance occurs when the voltage magnitude of the 3 phases is different. It is defined as the ratio of the negative phase sequence voltage to positive phase sequence voltage, expressed as a percentage. It is calculated as follows (reference standard ASAAJ3-1).

$$\text{Unbalance} = \frac{\sqrt{1 - \sqrt{3 - 6\beta}}}{\sqrt{1 + \sqrt{3 - 6\beta}}} \quad \text{where} \quad \beta = \frac{U_{AB}^4 + U_{BC}^4 + U_{CA}^4}{(U_{AB}^2 + U_{BC}^2 + U_{CA}^2)^2} \quad \text{and } U \text{ is the}$$

RMS line to line voltage


Single Phase Unbalance

22 kV 3 PHASE SYSTEM




THE EFFECT OF TWO PHASE LINE TAP-OFF FROM A 22 kV ESKOM LINE

Single Phase Unbalance



THE EFFECT OF TWO PHASE LINE TAP-OFFS FROM A 22 kV ESKOM LINE

Ferranti Effect




Ferranti Effect:		
Total Line Length	Charging Current	% Voltage rise
10 km	0.13 A	0.01%
50 km	0.65 A	0.15%
100 km	1.31 A	0.61%
200 km	2.67 A	2.40%
400 km	5.68 A	8.77%
600 km	8.95 A	14.34%

Break 3


Isolation Transformer

500 kVA ISOLATION TRANSFORMER FOR SWER SYSTEMS



SWER Customer Transformer

16 and 32 kVA TRANSFORMER, DUAL PHASE LV FOR 19.1 kV SWER SYSTEM



Break 4

Conductor options - Refer structures

- On the basis of limited (planned) loads, line lengths and upgrade paths normally light conductor range is applied –
- AAAC – Acacia.(7*2.08)
 - All aluminium alloy
 - Relatively low uts and strength dependant on all strands
 - Susceptible to vibration damage
 - Coastal and polluted areas
- ACSR – Squirrel (6/1*2.11)
 - Aluminium conductor steel reinforced
 - Cost effective flat terrain
- ACSR (extra strong) Magpie.(3/4*2.12)
 - Three aluminium, 4 steel strands
 - High uts value, relatively robust.
 - Ideal for long spans and undulating terrain.

Conductor options - Refer structures

Conductor	Point Load(minimum case)		Distributed load (typical case)	
	5%voltage-drop	10% voltage-drop	5% voltage-drop	10% voltage-drop
Fox	41 km	82 km	82 km	164 km
Squirrel	27 km	53 km	53 km	107 km
Magpie	14 km	28 km	28 km	56 km
Bantam	8 km	15 km	15 km	31 km

Assumption: Line lengths based on 25A load at 19,1kV.

Break 5

Determine the prospective life cycle loading on the affected system


- **Customer load estimating;**
 - **Design tools - Eskom has DT PET (applicable to SA situation) to enable parameter and pu electrification load determination – See design tools section.**
 - **Deterministic methods, calculation tables with diversity factors.**
 - **Forecast load growth on a time line, particularly emerging networks and mass electrification.**

Load estimation & project parameters


Criteria	Issue	Specified Minimum Requirement	Value offered	Reason and/or comments - CPE to provide short summary and design report	
MV System					
	Sys. Config:	SWER 2 phase 3 Phase	TBC TBC TBC	Yes Yes Yes	One spur of 17km Confirm the use of 2 Phase technology as per Planning Report - Utilised Acquirrel Two spurs proposed by planning report - 22km - constructed in 3 Phase (1740, 1
	Voltage intake at	As per Planning report: 33 Vilages	Design/No load 99%-102%	99%-102%	Where low load voltages exceed 100% , Maximum of 2,5% / 3% boost on 242V :
	Protection:	Recloser Reqd. Transformer switch Pole BIL wires reqd.	Yes Yes Yes	Yes Yes Yes	Required on the Mbashe Mqanduli 22kV network - Existing Take off at LNAK002 A link or MV Cut out unit per transformer supplied as per instruction. Confirmed c All intermediate structures except stayed and shared structures and structures in
	Voltage support	Regulator at: Capacitor at:	No No	No No	Not required. Not required.
Indicators					
	Scope	No of connections	2698	2698	
	Density	m ² /Connection	TBP	8897	Calculated from the overall layout
	ADMD (kVA)	Initial Final			Alternative: Initial Final Alpha 0.25 0.32 Comply
	CB setting	Initial Final			Beta 1.86 1.41 Comply CB 20 20 Comply
	DCF				ADMD 0.55 0.86 Comply
	UCF		As reqd.		Max trfr loading 130% - Setting in ReticMaster at AMEU currents.
	Maximum LV radial feeder length. (Limitation applies to 90 % of project)		550 m	750	Fault level at end of line within specification of 1.6x80A
	Protection	MV fuse sizes LV min fuse size		20 Amp 80 & 63 Amp	Group fusing - Fuse inserts - 20A K-type as per Eskom specification as per SLD EBM or HA Type as per Eskom standard specification. Mostly 80A fuses will be t
	Metering	LV/Bulk/Comb	Yes	No	Not required as per planning report.

Electrification distribution plan-Discussion example

Phase 1



Planning report - [Idutywa phase 5 Electrification.doc](#)




Phase 2

Idutywa S/S

MBASHE


Proposed configuration in terms of the electrification distribution plan including MV upgrade consideration (MV)




Break 6

SWER Upgrade options

- **Extend system –
Convert to 3 phase and
move isolation
transformer position.**
- **Split system at
isolation transformer
point (ideal as existing
electrodes are used.)**
- **New in feed positions
provided.**



Typical LV design, parameters and upgrade options



Calculation: ReticMaster
Nominal Voltage: 230V
Internal boost: 4.35%
Boost applied:
3% max (32kVA)
0% max (16kVA)
Trfr maximum load 130%

Upgrade:
Trfr zone stay as is
Trfr upgrade only
LV backbone upgrade only

Conclusion

For Rural electrification expansion

- Be mindful of the specific SWER constraints & SWER parameters
- Identify viable SWER schemes in the context of the emerging electrification plan
- Include phased implementation in the project motivation/specification

Thank you